

Translation

EU-Type Examination Certificate Supplement 1

Equipment intended for use in potentially explosive atmospheres
Directive 2014/34/EU

EU-Type Examination Certificate Number: **BVS 19 ATEX E 059 X**

Product: **Load-, Main-, and Safety switch type GHG 263 * * * * ***

Manufacturer: **Cooper Crouse-Hinds GmbH**

Address: **Neuer Weg Nord 49, 69412 Eberbach, Germany**

This supplementary certificate extends EU-Type Examination Certificate No. BVS 19 ATEX E 059 X to apply to products designed and constructed in accordance with the specification set out in the appendix of the said certificate but having any acceptable variations specified in the appendix to this certificate and the documents referred to therein.

DEKRA Testing and Certification GmbH, Notified Body number 0158, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential Report No. BVS PP 19.2127 EU.

The Essential Health and Safety Requirements are assured in consideration of:

EN IEC 60079-0:2018	General requirements
EN 60079-1:2014	Flameproof enclosure "d"
EN IEC 60079-7:2015 + A1:2018	Increased Safety "e"
EN 60079-11:2012	Intrinsic Safety "i"
EN 60079-31:2014	Protection by Enclosure "t"

If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Special Conditions for Use specified in the appendix to this certificate.

This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

The marking of the product shall include the following:

 **II 2G Ex db eb ia IIB/IIC T6 / T5 Gb**
II 2D Ex tb IIIC T80°C Db

DEKRA Testing and Certification GmbH
Bochum, 2020-03-18

Signed: Jörg-Timm Kilisch

Managing Director



13 **Appendix**
 14 **EU-Type Examination Certificate**

**BVS 19 ATEX E 059 X
 Supplement 1**

15 **Product description**

15.1 **Subject and type**

Load-, Main-, and Safety switch type GHG 263 *1) *2) **3) *4) ****5)

GHG Manufacturers marking

263 Switch 40 A

*1) Switch and enclosure version

- 1 = Main current switch / load switch – plastic version
- 2 = Safety switch – plastic version
- 3 = Main current switch / load switch – metal version
- 4 = Safety switch – metal version

*2) Number of switch contacts

- 3 = 3-pole
- 4 = 4-pole
- 5 = 5-pole
- 6 = 6-pole

**3) Equipment version

- 01 = Standard version
- 02 = Variant version
- ** = Specification by „Local-Assembly-Partner“

*4) Identification marking (country code) - Without influence on explosion protection

- R = Standard version
- * = Variant version (e.g. "X")

****5) Alphanumeric string - Without influence on explosion protection

15.2 **Description**

The load, main and safety switch type GHG 263 * * * * * is used for switching and disconnecting rated currents up to 40A. The main and safety switch type GHG 263 * * * * * is designed in type of protection "eb", Increased safety or "tb" protection by enclosure. Alternatively, circuits with intrinsic safety "i" protection can also be connected to the separately certified terminals or components.

The enclosure is made of plastic. Alternatively, a separately certified empty enclosure (PTB 99 ATEX 3118 U) made of plastic or metal can be used.

The enclosure is equipped with a separately certified load switch (BVS 14 ATEX E 085 U) in type of protection "db" flameproof enclosure and can optionally be equipped with an auxiliary switch (EPS 14 ATEX 1 688 U), indicator lamp (IBExU 12 ATEX 1047 U), Ex-d component (IBExU 14 ATEX 1030 U) and/or separately certified terminal block (PTB 00 ATEX 3102 U) or terminal strip (PTB 01 ATEX 1004 U).

Optionally, further separately certified terminals can be used according to the "List of components".

Reason for the supplement:

- The ambient temperature range was extended on the basis of subsequent tests.

15.3 Parameters

15.3.1 Electrical parameters

Nominal voltage		up to	690 V
Nominal current		up to	40 A
Nominal cross-section	main contact	16 mm ²	fine-stranded and stranded wire
		25 mm ²	stranded wire
		25 mm ²	flexible with special cable lug or additional clamping bracket
Nominal cross-section	auxiliary contact	35 mm ²	stranded with special cable lug or additional clamping bracket
		up to 4 mm ²	fine wire and stranded wire

15.3.2 Intrinsically safe parameters for signal lamp GHG 417 1805 R...

U_i	≤ 30 V
I_i	≤ 120 mA
C_i	0
L_i	0
P_i	≤ 750 mW

15.3.3 Ambient temperature range

IIC	$-20\text{ °C} \leq T_{amb} \leq +55\text{ °C}$
IIB / IIIC	$-55\text{ °C} \leq T_{amb} \leq +55\text{ °C}$
IIB	$-50\text{ °C} \leq T_{amb} \leq +55\text{ °C}$ (only safety switch for inverter drives)

Temperature class and surface temperature

≤ 4-pole version

connection cross-section	rated current	Ambient temperature and temperature class//surface temperature		
		+40 °C	+50 °C	+55 °C
6 mm ²	I_n up to 35 A	T6 / T80 °C	T6 / T80 °C	T6 / T80 °C
10 mm ²	I_n up to 35 A	T6 / T80 °C	T6 / T80 °C	T6 / T80 °C
	I_n up to 40 A	T6 / T80 °C	T6 / T80 °C	T5 / T80 °C
16 mm ²	I_n up to 40 A	T6 / T80 °C	T6 / T80 °C	T6 / T80 °C

> 4-pole version

connection cross-section	rated current	Ambient temperature and temperature class / surface temperature		
		+40 °C	+50 °C	+55 °C
6 mm ²	I _n up to 35 A	T6 / T80°C	T5 / T80°C	T5 / T80°C */**
10 mm ²	I _n up to 40 A	T6 / T80°C	T6 / T80°C	T5 / T80°C **
16 mm ²	I _n up to 40 A	T6 / T80°C	T6 / T80°C	T6 / T80°C

* Use cables and wires with a temperature resistance of more than 80 °C.

** Use cable glands with a temperature resistance of more than 70 °C.

16 **Report Number**

BVS PP 19.2127 EU, as of 2020-03-18

17 **Special Conditions for Use**

- The gap lengths of the flameproof gaps of the switching base are partly longer and the gap widths of the flameproof gaps are partly smaller than required in Table 2 and 3 of EN 60079-1:2014. Information on the dimensions can be obtained from the manufacturer.
- When combined with circuits of ignition protection type "I" - intrinsic safety, the clearances and creepage distances between intrinsically safe and non-intrinsically safe circuits in accordance with EN 60079-11:2012 must be maintained.

18 **Essential Health and Safety Requirements**


The Essential Health and Safety Requirements are covered by the standards listed under item 9.

19 **Drawings and Documents**

Drawings and documents are listed in the confidential report.

We confirm the correctness of the translation from the German original.
In the case of arbitration only the German wording shall be valid and binding.

DEKRA Testing and Certification GmbH
Bochum, 2020-03-18
BVS-Ret/Ar A20200101


Managing Director