



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX TUN 12.0029X** issue No.:1

Certificate history:
Issue No. 1 (2017-6-8)
Issue No. 0 (2013-2-14)

Status: **Current**

Date of Issue: **2017-06-08** Page 1 of 4

Applicant: **Baumer Hübner GmbH**
Max-Dohrn-Str. 2+4
10589 Berlin
Germany

Equipment: **Incremental encoder type EExHOG 161...**
Optional accessory:

Type of Protection: **Flameproof enclosures "d", increased safety "e"**

Marking: **Ex db eb IIC T6 Gb**

Approved for issue on behalf of the IECEx
Certification Body:

Christian Roder

Position:

Deputy Head of IECEx Certification Body

Signature:
(for printed version)

Date:

2017-06-08

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:





IECEx Certificate of Conformity

Certificate No.: IECEx TUN 12.0029X

Date of Issue: 2017-06-08

Issue No.: 1

Page 2 of 4

Manufacturer: **Baumer Hübner GmbH**
Max-Dohrn-Str. 2+4
10589 Berlin
Germany

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition: 6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2014-06 Edition: 7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-7 : 2015 Edition: 5.0	Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

DE/TUN/ExTR12.0036/00

DE/TUN/ExTR12.0036/01

Quality Assessment Report:

DE/TUN/QAR11.0011/03



IECEx Certificate of Conformity

Certificate No.: IECEx TUN 12.0029X

Date of Issue: 2017-06-08

Issue No.: 1

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The incremental encoder type EExHOG 161... is used for measuring the rotating speed of rotating electrical machines. It consists of a housing in the type of protection flameproof enclosures "d" with a terminal box in the type of protection increased safety "e".

Technical data

Permitted range of ambient temperature without shaft sealing (drawing no. 74141C)	-20 °C to +66 °C
Permitted range of ambient temperature with shaft sealing (drawing no. 74140C)	-20 °C to +58 °C
Maximum speed	5600 1/min
Rated voltage	to 30 V
Rated current without ballast	to 100 mA

SPECIFIC CONDITIONS OF USE: YES as shown below:

Repairs may only be carried out by the manufacturer.

The permitted range of ambient temperature is -20 °C to +58 °C and -20 °C to +66 °C. The valid ambient temperature is stated in the operating instructions.

The hexagon socket screws M4 x 16 and M5 x 20 have the property class 8.8.



IECEX Certificate of Conformity

Certificate No.: IECEx TUN 12.0029X

Date of Issue: 2017-06-08

Issue No.: 1

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

The marking changes as follows: Ex db eb IIC T6 Gb

The specific conditions of use have changed.