



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx CML 17.0135 Issue No: 0 Certificate history:  
Issue No. 0 (2017-12-14)

Status: **Current** Page 1 of 3

Date of Issue: **2017-12-14**

Applicant: **Rayrtec Ltd**  
Unit 15 Wansbeck Business Park  
Rotary Parkway  
Ashington, Northumberland  
NE63 8QW,  
United Kingdom

Equipment: **Spartan SPZ Floodlight/Bulkhead Luminaire**  
*Optional accessory:*

Type of Protection: **increased safety, encapsulation, flameproof, dust protected, optical radiation**

Marking:  
Ex ec mc op is IIC T4 Gc  
Ex tc op is IIIC T\*\*°C Dc  
Up to - 50 °C to +55 °C  
See description for specific marking and ambient temperatures

Approved for issue on behalf of the IECEx  
Certification Body:

H M Amos MIET

Position:

Technical Manager

Signature:  
(for printed version)

Date:

December 14, 2017

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**Certification Management Limited**  
Unit 1, Newport Business Park  
New Port Road  
Ellesmere Port, CH65 4LZ  
United Kingdom





# IECEX Certificate of Conformity

Certificate No: IECEX CML 17.0135 Issue No: 0

Date of Issue: 2017-12-14 Page 2 of 3

Manufacturer: **Raytec Ltd.**  
Unit 15 Wansbeck Business Park  
Rotary Parkway  
Ashington, Northumberland  
NE63 8QW,  
United Kingdom

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2011</b> Edition:6.0	Explosive atmospheres - Part 0: General requirements
<b>IEC 60079-1 : 2014-06</b> Edition:7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
<b>IEC 60079-18 : 2014</b> Edition:4.0	Explosive atmospheres – Part 18: Equipment protection by encapsulation "m"
<b>IEC 60079-28 : 2015</b> Edition:2	Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation
<b>IEC 60079-31 : 2013</b> Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
<b>IEC 60079-7 : 2015</b> Edition:5.0	Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[GB/CML/ExTR17.0186/00](#)

Quality Assessment Report:

[GB/SIR/QAR13.0018/04](#)



# IECEX Certificate of Conformity

Certificate No: IECEx CML 17.0135

Issue No: 0

Date of Issue: 2017-12-14

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The Spartan SPZ Floodlight/Bulkhead Luminaire is a range of LED lighting.

The enclosures are constructed using front, centre, and rear cast aluminium housings fixed using bolts. The front housing has a soda lime toughened glass lens available in clear or coloured options. A 'Vario' holographic diffuser film may be fitted behind the glass to give alternative light patterns. An optional replaceable antistatic lens film may be fitted.

The centre housing has either 1 or 2 independent encapsulated power supplies (electronic control gear) and terminal blocks for supply and internal connections. LED's are mounted on one or two independent Insulated Metal Substrate (IMS) PCBs attached to rear heat sink. Each PCB has 12 LED's that are either white, infra-red, coloured or a combination. An EMC filter module may be fitted as an optional extra, this is an additional encapsulated board, located in place of the terminal block bracket (when fitted).

The front and middle/rear housing of the luminaires may be split to allow the LED assembly to be mounted remotely from the power supply/emergency enclosure. There are internal and external earth points.

**See Annex for full description and Conditions of Manufacture**

**SPECIFIC CONDITIONS OF USE: NO**

### Annex:

[Certificate Annex IECEx CML 17.0135.pdf](#)

**Annexe to:** IECEx CML 17.0135 Issue 0  
**Applicant:** Raytec Ltd  
**Apparatus:** Spartan SPZ Floodlight/Bulkhead Luminaire



**Product Description**

The Spartan SPZ Floodlight/Bulkhead Luminaire is a range of LED lighting.

The enclosures are constructed using front, centre, and rear cast aluminium housings fixed using bolts. The front housing has a soda lime toughened glass lens available in clear or coloured options. A 'Vario' holographic diffuser film may be fitted behind the glass to give alternative light patterns. An optional replaceable antistatic lens film may be fitted.

The centre housing has either 1 or 2 independent encapsulated power supplies (electronic control gear) and terminal blocks for supply and internal connections. LED's are mounted on one or two independent Insulated Metal Substrate (IMS) PCBs attached to rear heat sink. Each PCB has 12 LED's that are either white, infra-red, coloured or a combination. An EMC filter module may be fitted as an optional extra, this is an additional encapsulated board, located in place of the terminal block bracket (when fitted).

The front and middle/rear housing of the luminaires may be split to allow the LED assembly to be mounted remotely from the power supply/emergency enclosure. There are internal and external earth points.

The following variant types are available:

Fixed (FL)	Fixed installation with above construction for use with mounting bracket. Fixing points are used for mounting bracket for fixing in any orientation and for additional mounting accessories.
Bulkhead (BL)	Wall mounting in any orientation using rear mounted steel brackets. The enclosure uses a modified FL variant light engine and has reduced height enclosure that houses a single power supply.
Transportable (FLT and BLT)	Fixed (FL) or Bulkhead (BL) luminaires mounted in tubular frame with suitable cable and separately certified gland, plugs and sockets.
Portable (FLP and BLP)	Fixed (FL) or Bulkhead (BL) luminaires mounted in tubular frame with suitable cable and separately certified glands and, plugs and sockets.
Fixed Emergency (FL ..-EM)	Medium Fixed (FL) Floodlight with extended rear housing incorporating an additional rechargeable battery pack, connection terminal block and encapsulated fuse
Bulkead Emergency (BL ..-EM)	Medium Bulkhead (BL) incorporating a rechargeable battery pack, connection terminal block and encapsulated fuse.

The variants are available in the following configurations:

***12	Small Floodlight
***24	Medium Floodlight
***48	Large Floodlight (2 x Medium FL24 fitted together horizontally or vertically with unions and alternative support brackets).
***72	Extra Large Floodlight (3 x Medium FL24 fitted together horizontally or vertically with unions and alternative support brackets).
Where *** = FL, BL, FLT, BLT, FLP or BLP variant and 12, 24, 48 and 72 are total the number of LED's	

Unit 1, Newport Business Park  
 New Port Road  
 Ellesmere Port  
 CH65 4LZ

T +44 (0) 151 559 1160  
 E info@cmllex.com

[www.cmllex.com](http://www.cmllex.com)

Company Reg No. 8554022 VAT No. GB163023642





All variants may be fitted with an optional encapsulated photocell. The EM variants may be fitted with a battery indicator LED.

Cable entries are provided for connection of the electrical supply for use with suitably certified cable glands. Alternatively, optional separately certified sockets of the following types may be mounted onto the back of an alternate luminaire enclosure and the certified ambient range of the equipment is limited to that of the type of socket fitted. When sockets are mounted onto the portable variants they are fitted with an essential carrying frame.

Description	Ambient Range	Certification Code		Socket Certificate Numbers	
		Gas	Dust	ATEX	IECEX
ATX Appleton PC//EN Socket	-20°C to +40°C	II 2 G Ex db e mb IIC	II 2 D Ex tD A21 IP66	LCIE 02ATEX0001U	IECEX LCI 07.0012U
Cooper CH GHG 54** Socket	-20°C to +40°C	II 2 G Ex db eb IIC	N/A	BVS 14ATEXE131U	IECEX BVS 14.0089U
Cooper CH GHG 5118	-50°C to +40°C	II 2 G Ex db eb IIC	II 2 D Ex tb IIIC Db	BVS 15ATEXE101U	IECEX BVS 15.0088U
Cooper CH GHG 5118	-20°C to +40°C	II 2 G Ex db e mb IIC	N/A	PTB 99ATEX1040U	IECEX BKI 04.0002
Stahl 8572/15-***-*	-50°C to +45°C	II 2 G Ex db eb IIC Gb	II 2 D Ex tb IIIC Db	PTB 16ATEX1016U	IECEX PTB 16.0028U
Stahl 8573/15-***-*	-50°C to +40°C	II 2 G Ex db eb IIC Gb	II 2 D Ex tb IIIC Db	PTB 16ATEX1018U	IECEX PTB 16.0030U

When used, the equipment ambient temperature range will be limited to the type of socket fitted.

The enclosures are available with the following power supply:

HV (High Voltage);	110 to 254 Vac / 154 to 355 Vdc
--------------------	---------------------------------

The following power supplies are available as options:

LV (Low Voltage);	18 to 48 Vac / 18 to 69 Vdc
ELV (Extra Low Voltage) rated	12 Vac/ Vdc

The following certification codes are used for the different power supply options:

The following variant are covered by this certification



Code	Description	Ambient Range (No Certified Sockets fitted)	Certification Code		Mounting Frame Required
FL12	Fixed Lighting - Small Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	NO
FL24	Fixed Lighting - Medium Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	NO
FL48	Fixed Lighting - Large Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	NO
FL72	Fixed Lighting - Extra Large Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	NO
BL24	Fixed Lighting - Small Bulkhead	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T98°C Dc	NO
FLT12	Transportable Lighting - Small Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	NO
FLT24	Transportable Lighting - Medium Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	NO
FLT48	Transportable Lighting - Large Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	YES
FLT72	Transportable Lighting - Extra Large Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	YES
BLT24	Transportable Lighting - Small Bulkhead	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T98°C Dc	NO
FLP12	Portable Lighting Small Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	NO
FLP24	Portable Lighting - Medium Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	NO
BLP24	Portable Lighting - Small Bulkhead	-50 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T98°C Dc	NO
FL24- ..-EM	Fixed Lighting - Emergency Floodlight	-20 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T82°C Dc	YES
BL24- ..-EM	Fixed Lighting - Bulkhead Emergency	-20 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T98°C Dc	YES
FL24- ..-LV	Fixed Lighting - Low Voltage	-20 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T98°C Dc	YES
BL24- ..-LV	Fixed Lighting - Bulkhead Low Voltage	-20 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T98°C Dc	YES
FL24- ..-ELV	Fixed Lighting - Extra Low Voltage	-20 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T98°C Dc	YES



Code	Description	Ambient Range (No Certified Sockets fitted)	Certification Code		Mounting Frame Required
BL24-...-ELV	Fixed Lighting - Bulkhead Extra Low Voltage	-20 °C to +55 °C	II 3 G Ex ec mc op is IIC T4 Gc	II 3 D Ex tc op is IIIC T98°C Dc	YES

Note: The equipment is marked 'op is' for EPL Gc and Dc applications. However, the equipment construction is considered to satisfy the requirements of 'Gb and Db' applications and has been marked in line with other associated equipment.

### Markings

#### No Certified Sockets Fitted:

##### FL\*\*

Ex ec mc op is IIC T4 Gc

Ex tc op is IIIC T82°C Dc

Ta = -50 °C to +55 °C

##### FL\*\* Emergency

Ex ec mc op is IIC T4 Gc

Ex tc op is IIIC T82°C Dc

Ta = -20 °C to +55 °C

##### BL\*\*

Ex ec mc op is IIC T4 Gc

Ex tc op is IIIC T98°C Dc

Ta = -50 °C to +55 °C

##### BL\*\* Emergency

Ex ec mc op is IIC T4 Gc

Ex tc op is IIIC T98°C Dc

Ta = -20 °C to +55 °C

#### Certified Sockets Fitted (except type GHG 54\*\*):

##### FL\*\* and FL\*\* Emergency

Ex dc ec mc op is IIC T4 Gc

Ex tb op is IIIC T82°C Db

Ta = See below

##### BL\*\* and BL\*\* Emergency

Ex dc ec mc op is IIC T4 Gc

Ex tb op is IIIC T98°C Db

Ta = See below

#### Certified Socket type GHG 54\*\* fitted:

##### FL\*\* and FL\*\* Emergency

Ex dc ec mc op is IIC T4 Gc

Ta = See below

##### BL\*\* and BL\*\* Emergency

Ex dc ec mc op is IIC T4 Gc

Ta = See below



A certified socket may be fitted as an option. The upper and lower ambient temperature ranges will be limited by the type of certified socket fitted as shown below and within the ambient temperature range of the equipment shown above.

**FL\*\* or BL\*\* excluding FL\*\* Emergency or BL\*\* Emergency**

Sockets type fitted:

PCX/EN 16A	Ta = -20 °C to +40 °C
GHG 54*** 16A	Ta = -20 °C to +40 °C
GHG 5118*** 16A (Latest)	Ta = -50 °C to +40 °C
GHG 5118*** 16A	Ta = -20 °C to +40 °C
8572/15-***-*	Ta = -50 °C to +40 °C
8573/15-***-*	Ta = -50 °C to +45 °C

**FL \*\* Emergency or BL \*\* Emergency**

Above socket type fitted	Ta = -20 °C to +40 °C
--------------------------	-----------------------

**Conditions of manufacture**

The following are conditions of manufacture

- i. Where the product incorporates certified components, the manufacturer shall ensure that any changes to those components do not affect the compliance of the certified product that is the subject of this certificate. A copy of the certificate and instructions for each separately certified part installed within the equipment shall be provided as part of the document pack with each arrangement supplied.
- ii. The manufacturer shall fit only the certified Ex Components listed in the Equipment Description in accordance with the certification documentation and the manufacturer's ratings and instructions. All Special Conditions of Certification/ Special Conditions for Safe Use/ Schedule of Limitations must be satisfied for each part fitted.
- iii. A dielectric strength test shall be carried out on all units manufactured in accordance with IEC 60079-7:2015 clause 7.1 and IEC 60079-18:2014, clause 9.2, at 1508 Vac for 1 minute, or alternatively at 1.2 times this test voltage for 100 ms. Alternatively, a 1.4 times d.c. voltage dielectric strength test may be carried out. No breakdown shall occur.  
Tests shall be carried out between each circuit and earth and between each circuit and the surface of encapsulated parts.
- iv. A visual inspection shall be carried out on the encapsulated parts to check for damage, in accordance with IEC 60079-18:2014, clause 9.1.

**Conditions of Certification/Special Conditions for Safe Use - None**