

Cooper Crouse-Hinds GmbH

Neuer Weg-Nord 49
69412 Eberbach, Germany

Telefon +49 (0)6271 806-0 (Zentrale)

Telefon +49 (0)6271 806-500 (Vertrieb Explosionsschutz)
Fax +49 (0)6271 806-476 (Vertrieb Explosionsschutz)

Internet www.ceag.de
E-Mail info-ex@ceag.de

Cooper Crouse-Hinds GmbH • Postfach 1563 • 69405 Eberbach



Herstellereklärung / Manufacturer declaration

Betriebsmittel :	PTB Zulassung:
Ex Drucktastersockel	PTB 97 ATEX 1081U
Ex Befehlsgeber	PTB 00 ATEX 3117
Ex Steuergeräte	PTB 99 ATEX 1044

Hiermit erklären wir in alleiniger Verantwortung, dass der Drucktaster GHG4171101R1 oder GHG4171101R3 in Verbindung mit dem verriegelten Schlagastervorsatz die in die Gehäusereihen GHG41, GHG43 und GHG44 ein- bzw. angebaut sind, bis zu einer SIL 3 Umgebung nach IEC 61508 eingesetzt werden können.

Apparatus	Certification
Ex Push button contact block	PTB 97 ATEX 1081U
Ex Control station	PTB 00 ATEX 3117
Ex Control Panel	PTB 99 ATEX 1044

With sole responsibility, we hereby declare, that the push button GHG4171101R1 or GHG4171101R3 in conjunction with the stay-put mushroom head actuator mounted in or on the GHG41, GHG43 and GHG44 series enclosures can be used in environments up to SIL 3 (Safety Integrity Level 3) according to IEC 61508.

COOPER Crouse-Hinds GmbH
Neuer Weg-Nord 47

69412 Eberbach

Datum : 22.04.04

Entwicklung :


I.A. Naumann

Entwicklungsleiter :


ppa. Schwarz