

EU DECLARATION OF CONFORMITY

No. 1A-EU-06/24-10

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**
Havlíčková 432
280 02 Kolín
Czech Republic
IČ: 61672971
DIČ: CZ61672971

declare under our sole responsibility that

product **Elektroinstallation fire resistant boxes**


type: **KSK 80, KSK 100, KSK 125, KSK 175**
variants: **Orange**

manufacturer: **KOPOS KOLÍN a.s. Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: Boxes and covers used for electric accessories for house and other similar fixed electrical installations.
Intended for installation in environments that require IP66 protection.
Clow wire test satisfies: the membrane at 850 ° C, the lid of the box at 850 ° C and the Box body at 650 ° C.
The needle burner test done
Temperature resistance boxes during installation is from -25 ° C to + 60 ° C.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:21+A11:21 cl. 14.1 and 14.3	Test Report No. 230637-01/01 of 26.04.2023 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	Test done: Rated insulation voltage 1000V
		ČSN EN IEC 60670-1 ed. 2:21+A11: ČSN EN 60670-1:05+Z1:10+A1:13+Z2:21 ČSN EN 60670-22:07	Test Report No. 222525-01/01 of 28.11.2022 Test Report corrected on 06.01.2023 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	

		ČSN EN 60670-1:05+Z1:10+A1:13 ČSN EN 60670-22:07	Test Report No. 702425-01/01 of 24.11.2017 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	
		ČSN EN 60670-1:05+A1:13 čl. 15.3	Test Report No. 403994-01/01 of 26.11.2014 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.
Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogy>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2018 and according to the National program „Safety Enterprise“.

Signed on behalf of KOPOS KOLÍN a.s.



Place of issue: Kolín, Czech Republic

Date of issue: 31.10.2024

Ing. Jana Dejmková
quality and ecology director

KOPOS KOLÍN a.s. 
Havlíčkova 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz